



BRIGHT WATER LABORATORY (OPC) PRIVATE LIMITED

Accredited by Kerala State Pollution Control Board

VIII/30B & B1, Potta Ashram Junction, Chalakudy, Thrissur-680722. Ph. No.:+919605275233, brightwaterlaboratory@gmail.com

TEST REPORT

page 1 of 1

Test Report No : BWL/TR/B693

Date Of Issue : 06-May-2025

Customer provided details

Customer Name : CRESCENT PUBLIC SCHOOL

Customer Address : Chalakudy

Phone No : 9895045661

Date Of Sample Received : 02-May-2025

Date of analysis : 02-May-2025 to 06-May-2025

Sample ID : Nil

Type of sample : Well water

Sample Quantity : 1.1L

Sample Drawn by : Customer

Sample Condition : Received In Good Condition

TEST RESULT

Sl No	PARAMETERS	UNIT	RESULTS	ACCEPTABLE LIMIT AS PER IS 10500 - 2012 RA 2023	TEST METHOD
PHYSICAL PARAMETER					
1	pH	-	6.50	6.5 - 8.5	IS: 3025 Part 11; 2022
2	Colour	Hazen Unit	Colourless	5	-
3	Odour	-	Agreeable	Agreeable	-
4	Turbidity	NTU	0.05	1	IS: 3025 Part 10; 2024
5	Total Dissolved Solids	mg/L	25.5	Max 500	IS: 3025 Part 16; 2023
6	Electrical Conductivity	µS/cm	37.1	No Limit	IS: 3025 Part 14; 2023
BACTERIOLOGICAL TEST					
7	Coliform	Coliform/100 ml	Absent	Absent	IS: 15185; 2021
8	E.coli	E.coli/100 ml	Absent	Absent	IS: 15185; 2021

Remarks : Satisfactory.

No of Parameters Tested : 8

*****End of the Report*****

ND : Not Detected
BDL : Below Detection Limit
TNTC : Too Numerous to Count

For Bright Water Laboratory (OPC) Pvt.Ltd

ANITTA SUNNY
Sr. Technologist
Authorized Signatory

Note : The test results are valid only for the sample provided and this report shall not be reproduced except in full, without the written approval of the laboratory.

Disclaimer: The laboratory has not been responsible for the sampling process, and the results apply only to the sample as received. Any inaccuracies in sample collection, transportation, or customer-provided information may affect the validity of the results.

H2/2058649/25

Chalakudy Municipality

Dated 18/06/2025

SANITATION CERTIFICATE

This is to certify that sanitation conditions of Crescent Public School 31/35C) Chalakudy Municipality is good & satisfactory. The latrine arrangements and the supply of drinking water are adequate and satisfactory.



Clean City Manager

Chalakudy Municipality